



SUPPLY CHAIN MANAGEMENT

Enquiries: Ms. I Thesen

Ref: 6/4/2

Tel: (021) 808 8720

E-mail: Ingrid.thesen@stellenbosch.gov.za

As per e-mail:

Dear Sir /Madam

NOTICE TO BIDDERS

ADDENDUM: TENDER B/SM 46/22: CONSTRUCTION OF THE LA TERRA 11KV SWITCHING STATION IN THE FRANSCHHOEK AREA OF STELLENBOSCH

The compulsory site meeting held on Friday, 3 June 2022 at 10h00 at the Municipality's office located at La Rochell Street, Franschhoek, has reference.

1. Replace the Item 4.5 (Page 227 of 369):

4.5	11kV Indoor Busbar Rating	Unit	QTY
	11kV Indoor Cu Busbar Rated at 1250A	each	2

With:

4.5	Exhaust Ducts	Unit	QTY
	Install Exhaust Ducts for the 11kV GIS Indoor Metal Clad Switchgear	sum	1

2. Add the Item 5.4 (Page 228 of 369):

No current information – additional new item

With:

5.1	Single mode Fibre (24 core) for differential protection	Unit	QTY
a	Single-mode indoor-outdoor 1310nm (unarmoured)	m	6000
b	32mm fibre duct	m	6000
c	Install, excavate and reinstate trenches	m	6000

The following Questions were raised at the site meeting and were answered as follows:

Question 1: Clarify item 4.5

Answer: *Will be removed and replaced*

Question 2: Installation of Switchgear

Answer: *Covered under item 7.1.1*

Question 3: Specification calls for differential protection on incomer and feeders

Answer: Covered under item 5.4 in the BoQ

**DIRECTOR
CORPORATE SERVICES**

DATE:

10/6/22



Note: Confirmation to the addendum

CONFIRMATION

I (Name) hereby declare on behalf of
..... (Company's name),
to agree/not agree (please encircle) to the above changes in the bidding documentation.

Address:
.....
.....

Tel no.:

Fax no.:

Signature of bidder:

Date:

.....