



SUPPLY CHAIN MANAGEMENT

Enquiries: Ms. I Thesen

Ref: 6/4/2

Tel: (021) 808 8720

E-mail: Ingrid.thesen@stellenbosch.gov.za

As per e-mail:

Dear Sir /Madam

NOTICE TO BIDDERS

ADDENDUM: TENDER B/SM: BSM 102/23

DESIGN, MANUFACTURE, SUPPLY, DELIVERY, OFFLOADING AND INSTALLATION OF MEDIUM VOLTAGE METAL ENCLOSED SWITCHGEAR AND RING MAIN UNITS FOR THE PERIOD UP TO JUNE 2026

Please note that the following answer provided at the clarification meeting on 28/06/2023 is confirmed.

Question 1:

The panel Rated short time withstand current of 20kA is required. Would a lower than 31.5kA Rated short time withstand current for the circuit breaker be acceptable.

Answer:

This would not be possible to change now as the GMR 2 electrical engineer needs to investigate and approve the change of this value.

NOTE:

It is further confirmed that no changes to the specifications have been approved.

It is further confirmed that extension of the closing date was not approved and remains 17 July 2023.

**DIRECTOR
CORPORATE SERVICES**

DATE:

14/07/23



Note: Confirmation to the addendum

CONFIRMATION

I (Name) hereby declare on behalf of
..... (Company's name),
to agree/not agree (please encircle) to the above changes in the bidding documentation.

Address:
.....

Tel no.:
Fax no.:

Signature of bidder:

Date: